

premier
guarantee[®]

SYSTEM APPROVAL

Product Name: M2 EMMEDUE Advanced Building System



Conditions of Approval:

- 1) The ETA certificate ref 16/0264 remaining valid.
- 2) Works being in strict accordance with the ETA certificate.
- 3) Construction is carried out by competent installers who have carried out sufficient training in the Emmedue system, details will be required.
- 4) We will accept the use of M2 EMMEDUE Advanced Building System, provided it is finished with Euromix Prospray, in accordance with the Lucideon Test Report Reference: 184359.
- 5) The System is not acceptable for use below ground level.
- 6) We will accept the use of M2 EMMEDUE Advanced Building System, provided it is installed, used and maintained in accordance with our Technical Manual.
- 7) Structural calculations are provided on a project specific basis.
- 8) Foundation design to be provided on a project specific basis.
- 9) That sound testing is carried out on a project specific basis in accordance with Approved Document E.
- 10) SAP calculations are provided on a project specific basis.
- 11) Part M compliance is assessed on a project specific basis.
- 12) Part B compliance is assessed on a project specific basis.
- 13) Manufacturer's specification and warranty is to be provided to the plan check team, on a project specific basis, together with third party accreditation for all external doors and windows.
- 14) Stairs and landings will be checked on a project specific basis depending on the internal layout of the dwelling.

Cert No: GLP0418

Valid Until: 19/12/19

Summary: Panels of steel wires with incorporated thermal insulation for a whole structure.

Use: Any project exceeding 3 storeys, will need to be referred to the Research and Development team.